

PART 1 - GENERAL

1.1 PROJECT – H17-9609-MJ-A

- A. CCU –SOCCER COMPLEX – FIELD LIGHTING

1.2 ENGINEER

- A. DWG Consulting Engineers, Inc.
1009 Anna Knapp Blvd, Mt. Pleasant, SC 29464
(843) 849-1141

1.3 RELATED DOCUMENTS

- A. This Addendum consists of 2 pages.
- B. To Prime Bidders of Record:
 - 1. This addendum forms a part of the Contract Documents and modifies the original Project Manual and Drawings. Acknowledge receipt of this addendum on the Bid Form. Failure to do so may cause a bid to be rejected as unresponsive as outlined in the Instructions to Bidders.

PART 2 - ADDENDUM ITEMS

2.1 GENERAL

- A. The following changes/clarifications shall be made to the Project Manual:
 - 1. In Section 265600 EXTERIOR LIGHTING, part 1.2.A LIGHTING PERFORMANCE, the following modified chart shall be included. The modified portion is highlighted for end camera Average Target Illumination Levels, meeting NCAA Regional Broadcast Levels.

Area of Lighting	Average Target Illumination Levels	Maximum to Minimum Uniformity Ratio	Grid Points	Grid Spacing
Soccer	75 fc (horizontal)	2:1	96	30' x 30'
Soccer	75 fc (vertical – main camera)	2:1	96	30' x 30'
Soccer	45 fc (vertical – end camera)	7:1	96	30' x 30'

All above light levels must be shown in order to comply with NCAA Best Practices - Regional Broadcast Levels.

ADDENDUM NO. 1
September 14, 2022

2. In Section 265600 EXTERIOR LIGHTING, part 4.0.B, subject to meeting requirements of the contract documents, Premiere Sports Lighting (PSL) shall be added to the list of pre-approved manufacturers.

B. Questions:

1. Q: The Stainless-Steel poles are noted, but the Unistrut is specified as Galvanized, do we need to go with stainless steel or galvanized on the strut?
A: The horizontal strut will be galvanized steel as indicated on the drawings.
2. Q: Is the Buck-Boost XFMR provided by customer, if not, are there any specifications listed on the drawings of in the bid package?
A: The Buck-Boost XFMR is contractor provided. Basis of design can be found at note 3 in the equipment notes under the equipment connection schedule.
3. Q: Will all the telecom material and equipment be provided by the customer, if so, is that to be a separate bid? Are there any inside wiring or landing of communications devices?
A: Only the rough-in for telecom will be provided at this time.
4. Q: Will the scoreboard be provided as part of this work?
A: The scoreboard shall not be provided as part of this work. Power circuiting and telecom rough-in shall be provided for a future scoreboard.

END OF ADDENDUM NO. 1